Annexure - II

Test Certificate Form (to be filled by the licensed electrical contractor)

I hereby decl	lare that –
(a) I 	
(b) I I	umber ishave completed this work for Mr/Mrs/Ms For is building at
 ca th H st re	The work was arried out under the supervision of
(c) To	esting of consumer's installation has been done as per the Regulation 31 of entral Electricity Authority (Measures relating the safety and electric supply) egulations, 2010.
(d) A sa in	s per the Regulation 33 of Central Electricity Authority (Measures relating the afety and electric supply) Regulations, 2010, all the equipments have the sulation Resistance value as stipulated in the relevant Indian Standards. i.e. nore than 1 Mega Ohm as per clause 12.3.5 of IS 732-1989.
(e) Ti of	he insulation resistance between the exposed conductive parts and all live parts f the equipments are measured separately and certified that the value is not less can 0.5 Mega Ohm.
Date:	Signature of the licensed contractor with seal
Details of departure if any from Regulations:	